



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board San Diego Region



Arnold Schwarzenegger
Governor

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

October 13, 2009

Ms. Milica Kaludjerski, Unit Manager
County of San Diego
5555 Overland Ave., STE 2188
San Diego, CA 92123-1295

CERTIFIED MAIL

~~7000 0020 0001 7100 0020~~
7008 1140 0002 4285 4077
In reply refer to:
255440:adai

Dear Ms. Kaludjerski:

SUBJECT: NOTICE OF VIOLATION NO. R9-2009-0169, SAN PASQUAL ACADEMY

Enclosed is Notice of Violation (NOV) No. R9-2009-0169 for the discharge at the San Pasqual Academy. The basis for issuing this NOV was the monitoring data contained in the January-June 2009 semiannual monitoring report documenting concentrations of constituents in the effluent had exceeded the specifications of Order No. 94-04.

Please take steps to implement the follow-up actions necessary to ensure that the violations noted do not occur in the future. These violations subject the County of San Diego (County) to possible further enforcement action by the California Regional Water Quality Control Board, San Diego Region, including administrative enforcement orders requiring the County to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.


The next monitoring reports are the July-December 2009 semi-annual and January-December 2009 annual monitoring reports, which are due by January 30, 2010. In the subject line of any response, please include the requested "in reply refer to:" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Ms. Cathryn Henning at (858)-636-3161 or at chenning@waterboards.ca.gov.

Sincerely,

Julie Chan P.G.
Supervising Engineering Geologist
Groundwater Basins Branch

JC:rwm:clh:ad

¹ Under authority of California Water Code section 13350.



IN THE MATTER OF

County of San Diego
San Pasqual Academy
5555 Overland Ave. STE 2188
San Diego, CA 92123-1295

)
)
)
)
)
)

NOTICE OF VIOLATION
NO. R9-2009-0169

In reply refer to:
255440: adai

Waste Discharge Requirements: Order No. 94-04
Facility: San Pasqual Academy

YOU ARE HEREBY NOTIFIED THAT:

The County of San Diego (County) violated Order No. 94-04, *Waste Discharge Requirements for Southern California Conference Seven-Day Adventist, San Pasqual Academy, San Diego County*. These violations subject the County to possible further enforcement action by the California Regional Water Quality Control Board, San Diego Region (Regional Board), including administrative enforcement orders requiring the Society to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;² referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The Regional Board noted the following violations in reviewing the January-June 2009 semi-annual monitoring report required by Order No. 94-04:

Summary of Violations

1. There were 2 violations of Discharge Specification B.1 of the daily maximum effluent concentration of total suspended solids (TSS), established at 45 milligrams per liter (mg/L). The violations occurred on April 16, and May 12, 2009 with reported values of 47.5 mg/L and 60.3 mg/L, respectively.
2. There were 3 violations of Discharge Specification B.1 of the 30-day average effluent concentration of total suspended solids (TSS), established at 30 mg/L. The violations occurred for March, April, and May 2009 with reported values of 40.1 mg/L, 47.5 mg/L, and 60.3 mg/L, respectively.
3. There was 1 violation of Discharge Specification B.1 of the 30-day average effluent concentration of total dissolved solids (TDS), established at 800 mg/L. The violation occurred for June 2009 with a reported value of 820 mg/L.
4. There were 12 violations of Discharge Specification B.1 of the daily maximum and 30-day average effluent concentration of chloride, established at 150 mg/L


² Under authority of California Water Code section 13350.

and 130 mg/L, respectively. The violations occurred on January 12, February 12, March 12, April 16, May 12, and June 11, 2009 with reported values of 178 mg/L, 152 mg/L, 213 mg/L, 199 mg/L, 161 mg/L, and 206 mg/L, respectively.

5. There were 2 violations of Discharge Specification B.1 of the daily maximum and 30-day average effluent concentration of sulfate, established at 150 mg/L and 130 mg/L, respectively. The violations occurred on February 12, 2009 with reported value of 134.0 mg/L.

Questions pertaining to the issuance of this Notice of Violation are to be directed to Cathryn Henning at (858)-636-3161 via e-mail at chenning@waterboards.ca.gov. Written correspondence should be directed to the following address:

Ms. Julie Chan
Supervising Engineering Geologist
California Regional Water Quality Control Board, San Diego Region
9174 Sky Park Court, Suite 100
San Diego, CA 92123-4340



Julie Chan, P.G.
Supervising Engineering Geologist
Groundwater Basins Branch

Oct. 13, 2009
DATE

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

County of San Diego
 5555 Overland Ave, STE 2188
 San Diego, CA 92123-1295

2. Article Number

(Transfer from service label)

7008 1140 0002 4285 4077

COMPLETE THIS SECTION ON DELIVERY

A. Signature

X

- Agent
- Addressee

B. Received by (Printed Name)

C. Date of Delivery

D. Is delivery address different from item 1? Yes

If YES, enter delivery address below: No

3. Service Type

- Certified Mail Express Mail
- Registered Return Receipt for Merchandise
- Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee)

Yes

PLACE STICKER AT TOP OF ENVELOPE TO THE RIGHT OF THE RETURN ADDRESS, FOLD AT DOTTED LINE
CERTIFIED MAIL™



7008 1140 0002 4285 4077
 7008 1140 0002 4285 4077
 7008 1140 0002 4285 4077

U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT
 (Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com

OFFICIAL USE

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark Here

Sent To
 County of San Diego (Ms. Mica Kaludjerski)
 Street, Apt. No., or PO Box No.: 5555 Overland Ave., STE 2188
 City, State, ZIP+4
 San Diego, CA 92123-1295